

BURY COUNCIL
DEPARTMENT FOR OPERATIONS

REF NO: 22/284

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 68801

Location: Bury College, Market Street, Bury, BL9 0BG

Development: 3 No. internally illuminated fascia signs and 1 No. free standing internally illuminated double sided totem sign;
Letters sign above entrance

RECOMMENDATION

I recommend that any planning permission given shall include the following condition:

The luminance of the fascia and free standing signs shall not exceed 300cd/m² each.
(ADL1 Amended)

Reasons

To avoid undue distraction to traffic in the interests of road safety and to protect the amenity of adjoining occupiers.

Comments and Observations

Date: 24 October 2022

Signed: **A Southgate**
(pp) Head of Engineering

HIGHWAYS ASPECTS ONLY