

The noise assessment has been carried out in accordance to relevant British Standards for noise. The conclusion is that the site is suitable as long as the mitigation methods are implemented:

- Non glazed elements minimum acoustic performance 50(dB Rw)
- Glazing minimum single figure weighted sound reduction 28dB
- Standard trickle vents