



The Compliance Company

4-6 SILVER STREET BURY

Environmental Noise Assessment for Change
Of Use from Commercial to Hot Food Takeaway

Address

4-6 Silver Street, Bury, BL9 0EX

Office 8094, 321-323 High Road,
Chadwell Heath, Essex, RM6 6AX

www.redfansolutions.co.uk
info@redfansolutions.co.uk

Report Number 2526-1000-02-03-01

Overview

Site Address: 4-6 Silver Street, Bury, BL9 0EX

Report no: 2526-1000-02-03-01

Date of Report: 03/01/2026

Authors: Andrew Hunt

Prepared by: REDFAN Solutions
www.redfansolutions.co.uk
info@redfansolutions.co.uk
for
The Compliance Company
Ivy Business Centre, Crown Street
Manchester, M35 9BG
Tel: 0161 410 1482
compliance@thecompliancecompany.uk

Document Revisions			
Issue Number	Current Status	Date	Stage
V1	Planning	03/01/2026	First

This report has been prepared by REDFAN Solutions with all reasonable expertise, care and diligence. The survey and report have been undertaken in accordance with accepted acoustic consultancy principles, it takes account of the services and terms and conditions agreed verbally and in writing between REDFAN Solutions and our client. Any information provided by third parties and referenced is considered to have undergone suitably thorough third-party checks to ensure accuracy. We can accept no liability for errors with third - party data. This report is confidential to our client and therefore REDFAN Solutions accepts no responsibility whatsoever to third parties unless formally agreed in writing by REDFAN Solutions. Any such party relies upon the report at their own risk.

Contents

Cover Page

Overview

Contents

1. Introduction
2. Criteria
3. Site Description and Observations of Industrial Noise and Other Potential Noises
4. Environmental Noise Survey
5. Uncertainty
6. Results
7. Assessment of noise breakout
8. Assessment of extraction noise
9. Assessment of Partition from commercial to residential Spaces
10. Conclusions

Appendices

- A. Common Environmental Acoustic Indices
- B. Environmental Noise Results
- C. Site Plan

1. Introduction

- 1.1 REDFAN Solutions have been instructed to assess the background noise and impact on the proposed new hot food takeaway at ground level at 4-6 Silver Street, Bury, OL9 0EX.
- 1.2 Planning consent is being sought for the change of use at ground level to include hot food takeaway.
- 1.3 A noise impact report and assessment will be part of the application for the Local Authority to demonstrate that the amenity of occupiers is not adversely affected by noise.
- 1.4 This report outlines the background noise levels at the site as well as also providing any acoustic performance specifications that are required to enable the internal noise criteria to be achieved.
- 1.5 Monitoring of the prevailing background noise was undertaken over a 4-day period.

2. Criteria

- 2.1 Part 1 and 2 of BS 7445 establishes guidelines to quantities and procedures for environmental noise measurements and a guide to the acquisition of data pertinent to land use. Guidance provided on instrumentation and calibration, measurement positions, meteorological effects, and information to be recorded.
 - 2.1.1 All equipment shall be calibrated and the configuration for calibration shall be in accordance with the manufacturer's instructions.
 - 2.1.2 A comprehensive recalibration at certain time intervals may be prescribed by authorities responsible for the use of measurement results.
 - 2.1.3 A field check shall be made by the user at least before and after each series of measurements, preferably including an acoustic check of the microphone.
 - 2.1.4 "Outdoor measurements near buildings": these measurements shall be carried out at places where the noise to which a receiver is exposed is of interest. If not otherwise specified, the preferred measurement positions are 1m to 2m from the façade and 1.2m to 1.5m above the ground.
 - 2.1.5 Measurements indoors. These measurements shall be carried out in enclosures where the noise is of interest. At least 1m away from walls and 1.2m to 1.5m above the ground.

2.2 Government guidelines for planning assessment is the National Planning Policy Framework (NPPF) which came into force in March 2012, in July 2018 and the National Planning Policy Guidance (NPPG). This was undated and in the main replaces previous PPG and PPS documentation.

2.3 The NPPF 2024 sets out the Government's economic, environmental and social planning policies for England and Paragraph 187-part e states,

"preventing new and existing development from contributing to, being put at unacceptable risk from, or being adversely affected by, unacceptable levels of soil, air, water or noise pollution.

Paragraph 198 part a states,

Planning policies and decisions should also ensure that new development is appropriate for its location taking into account the likely effects (including cumulative effects) of pollution on health, living conditions and the natural environment, as well as the potential sensitivity of the site or the wider area to impacts that could arise from the development. In doing so they should:

a) mitigate and reduce to a minimum potential adverse impacts resulting from noise from new development – and avoid noise giving rise to significant adverse impacts on health and the quality of life;

b) identify and protect tranquil areas which have remained relatively undisturbed by noise and are prized for their recreational and amenity value for this reason;

2.4 BS 4142: 2014+A1:2019 "Method for rating and assessing industrial and commercial sound".

This British Standard describes methods for rating and assessing sound of an industrial and/or commercial nature, which includes:

- sound from industrial and manufacturing processes;
- sound from fixed installations which comprise mechanical and electrical plant and equipment;
- sound from the loading and unloading of goods and materials at industrial and/or commercial premises;
- sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from premises or processes, such as that from forklift trucks, or that from train or ship movements on or around an industrial and/or commercial site.

The significance of sound impact is to be determined according to the following summary process:

- Determine the background sound levels, in terms of the index LA90, at the receptor locations of interest.
- Determine the specific sound level of the source being assessed, in terms of its LAeqT level (T = 1 hour for day or 15 minutes for night), at the receptor location of interest.
- Apply a rating level acoustic feature correction if the source sound has tonal, impulsive, intermittent, or other characteristics which attract attention.
- Compare the rating sound level with the background sound level; the greater the difference between the two, the higher the likelihood of adverse impact.
- A difference (rating – background) of around +10 dB is an indication of significant adverse impact, depending on the context; a difference of +5 dB is an indication of an adverse impact, depending on the context. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending upon context.

2.5 BS 4142 introduced the concept of 'context' to the process of identifying noise impact. Section 11 of BS 4142: 2014+A1:2019 explains "The significance of sound of an industrial and/or commercial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs" (our emphasis). An effective assessment cannot be conducted without an understanding of the reason(s) for the assessment and the context in which the sound occurs/will occur. When making assessments and arriving at decisions, therefore, it is essential to place the sound in context" (our emphasis).

There are many context points to consider when undertaking an assessment of sound impact including:

- The absolute level of sound;
- The character and level of the specific sound in the context of the existing noise climate; for example, is the sound to occur in a location already characterised by similar activities as those proposed?
- The sensitivity of the receptors;
- The time and duration that the specific sound is to occur;
- The conclusions of assessments undertaken using alternative assessment methods, for example, WHO guidelines noise values or change in noise level;

2.6 BS4142:2014+A1:2019 notes that:

"Adverse impacts include, but are not limited to, annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact." BS4142:2014+A1:2019 outlines

guidance for the consideration of the context of the potential impact including consideration of the existing residual sound levels, location and/or absolute sound levels.

To account for the acoustic character of proposed sound sources, BS4142:2014+A1:2019 provides the following with respect to the application of penalties to account for *"the subjective prominence of the character of the specific sound at the noise-sensitive locations and the extent to which such acoustically distinguishing characteristics will attract attention"*.

- **Tonality** – *"For sound ranging from not tonal to predominantly tonal the Joint Nordic Method gives a correction of between 0dB and +6dB for tonality. Subjectively, this can be converted to a penalty of 2dB for a tone which is just perceptible at the noise receptor, 4dB where it is clearly perceptible and 6dB where it is highly perceptible;*
- **Impulsivity** – *A correction of up to +9dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively, this can be converted to a penalty of 3dB for impulsivity which is just perceptible at the noise receptor, 6dB where it is clearly perceptible, and 9dB where it is highly perceptible;*
- **Intermittency** – *When the specific sound has identifiable on/off conditions, the specific sound level ought to be representative of the time period of length equal to the reference time interval which contains the greatest total amount of on time. If the intermittency is readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied; and*
- **Other Sound Characteristics** – *Where the specific sound features characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied."*

2.7 It is therefore entirely possible that whilst the numerical outcome of a BS 4142: 2014+A1:2019 assessment is indicative of adverse or significant adverse impact, when the proposal is considered in context the significance of the impact is reduced to an acceptable level.

2.8 The NPPG introduces the concept of a noise exposure hierarchy based on likely average response. The guidance contained in the NPPG is summarised in the table below:

Table 1: Noise Exposure Hierarchy Perception Examples

Perception	Examples of Outcomes	Increasing Effect Level	Action
No Observed Effect Level			
Noticeable and Intrusive	No Effect	No Observed Effect	No specific measures required
No Observed Adverse Effect Level			
Noticeable and not intrusive	Noise can be heard but does not cause any change in behaviour or attitude. Can slightly affect the acoustic character of the area but not such that there is a perceived change in the quality of life.	No Observed Adverse Effect	No specific measures required
Lowest Observed Adverse Effect Level			
Noticeable and Intrusive	Noise can be heard and causes small changes in behaviour and/or attitude, e.g. turning up volume of television; speaking more loudly; where there is no alternative ventilation, having to close windows for some of the time because of the noise. Potential for some reported sleep disturbance. Affects the acoustic character of the area such that there is a perceived change in the quality of life.	Observed Adverse Effect	Mitigate and reduce to a minimum
Significant Observed Adverse Effect Level			
Noticeable and Disruptive	The noise causes a material change in behaviour and/or attitude, e.g. avoiding certain activities during periods of intrusion; where there is no alternative ventilation, having to keep windows closed most of the time because of the noise. Potential for sleep disturbance resulting in difficulty in getting to sleep, premature awakening and difficulty in getting back to sleep. Quality of life diminished due to change in acoustic character of the area.	Significant Observed Adverse Effect	Avoid
Noticeable and very disruptive	Extensive and regular changes in behaviour and/or an inability to mitigate effect of noise leading to psychological stress or physiological effects, e.g. regular sleep deprivation/awakening; loss of appetite, significant, medically definable harm, e.g. auditory and non-auditory.	Unacceptable Adverse Effect	Adverse Effect Prevent

2.9 In March 2010 the Department for Environment, Food and Rural Affairs (DEFRA) produced "Noise Policy Statement for England" (NPSE), which states three policy aims, as follows:

"Through the effective management and control of environmental, neighbour and neighbourhood noise within the context of Government policy on sustainable development:

- avoid significant adverse impacts on health and quality of life;
- mitigate and minimise adverse impacts on health and quality of life; and

- where possible, contribute to the improvement of health and quality of life."

2.10 The "Noise Policy Statement for England", (NPPF) and (NPPG) state that no significant adverse impact should occur through development, but where noise levels fall between a lowest observable adverse effect and a level which represents a significant observed adverse effect, then according to the explanatory notes in the statement:

"... all reasonable steps should be taken to mitigate and minimise adverse effects on health and quality of life whilst also taking into consideration the guiding principles of sustainable development. This does not mean that such effects cannot occur."

2.11 BS8233:2014 Local Authorities usually stipulate internal noise criteria for new build residential uses based on British Standard 8233:2014 'Guidance on Sound Insulation and Noise Reduction for Buildings'.

2.12 BS 8233:2014 provides references and guideline values for desirable indoor ambient noise levels for dwellings as shown in Table 2.9 below.

2.13 BS 8233:2014 Desirable Internal Ambient Noise Levels for Dwellings

Table 4 Indoor ambient noise levels for dwellings

Activity	Location	07:00 to 23:00	23:00 to 07:00
Resting	Living room	35 dB $L_{Aeq,16hour}$	—
Dining	Dining room/area	40 dB $L_{Aeq,16hour}$	—
Sleeping (daytime resting)	Bedroom	35 dB $L_{Aeq,16hour}$	30 dB $L_{Aeq,8hour}$

2.14 The table is noted to apply to external noise as it affects the internal acoustic environment from sources without a specific character.

2.15 The above internal ambient noise levels are therefore considered appropriate within this assessment.

2.16 BS 8233:2014 states that 'for traditional external areas that are used for amenity space, such as gardens and patios, it is desirable that the external noise level does not exceed an upper guideline value of 55dB L_{Aeq} , which would be acceptable in noisier environments. However, it is also recognized that these guideline values are not achievable in all circumstances...in higher noise areas, such as city centres or urban areas adjoining the strategic transport network, a compromise between elevated noise levels and other factors, such as the convenience of living in these locations or making efficient use of land resources to ensure development needs can be met, might be warranted. In such a situation, development should be designed to achieve the lowest practicable levels in these external amenity spaces but should not be prohibited'.

2.17 The following table summarises the response to changes in noise level (known as the Semantic Scale).

Table 2: Change in noise level – response and impact.

Change in noise level LAeqT dB	Response	Impact
<3	Imperceptible	None
3 – 5	Perceptible	Slight
6 – 10	Up to a doubling	Significant
11 – 15	More than a doubling	Substantial
> 15	-	Severe

2.18 For good sleep, it is believed that indoor sound pressure levels should not exceed approximately 45dB LAmax more than 10–15 times per night.

2.19 WHO Guidelines for Community Noise

- 2.19.1 The WHO Guidelines (1999) recommends indoor nighttime guidelines in order to avoid sleep disturbance, the document states these to be 30dB (LAeq) and 45dB (LAfmax) for continuous and individual noise events respectively.
- 2.19.2 The document states that the number of noise events should also be considered and that individual noise events should not exceed 45dB (LAfmax) more than 10 – 15 times per night.

3. Site Description and Observations

- 3.1 The proposed construction area hereafter referred to as 'the site', is a High Street ground floor premises which in the past has been used as offices. This existing ground floor commercial space on Silver Street is applying to be turned into a hot food takeaway. The site sits on the corner of Silver Street and Parks Yard.
- 3.2 There are commercial offices directly above the proposed site.
- 3.3 The development of a hot food takeaway restaurant will have residential noise sensitive receptors nearby. This assessment has been raised with regard to potential noise disturbance from the operation of the restaurant on these residential occupants. As part of these assessments, typical noise levels within similar sized premises will be used in order to assist the assessment of noise break-out from the premises and noise from plant equipment at the nearest NSR.
- 3.4 The development is on a city centre commercial road with traditional shops, pubs and restaurants at ground level with a mix of residential and offices above. Silver Street is a one-way, slow-moving speed-controlled road with parking either side and wide pavements. The road skirts the outside of the main shopping area and is generally not a cut through for traffic.

Noise Sources

- 3.5 The noise survey was unmanned; therefore, a subjective assessment of background and ambient noise sources could not be undertaken for the whole monitoring duration. While onsite the dominant noise source was road traffic, pedestrians and people using the shops nearby. Secondary noise was from birds and the general hum associated with towns.
- 3.6 Red lines outline approximate site and survey position.



4. Environmental Noise Survey

4.1 The unattended survey was undertaken between 11:00 on 13/11/2025 to 07:00 on 17/11/2025. A full weekend was observed.

4.2 Ambient (L_{Aeq}), (L_{A90}), (L_{cfMax}) and (L_{cfMax}) level measurements were taken for a continuous 1-hour period in 5- and 15-minute increments.

4.3 The recordings were taken in 5 minute and 15-minute intervals to prevent any other single noises that would be seen as not representational from affecting the measurements. Prior knowledge of any out of the ordinary potential noise was limited and could have had an impact on the test.

4.4 The sound level meter was not positioned as for an outdoor free field measurement. The microphone was not between 1.2m to 1.5m above the ground therefore a 3dB reduction will be included to account for reverberation of the façade of the building. The position was chosen to best represent the ambient noise environment in particular for the Bar below.

4.5 Equipment used for the survey.

Item	Make/Model	Serial No	Calibration Cert No
Calibrator	Norsonic 1255	125526735	U52418
Sound Level Meter	Norsonic 140	1404818	U46539

4.6 Measurements were made following procedures in BS7445:1991 (ISO1966-2:1987) Description and Measurement of Environmental Noise Part 2- Acquisition of data pertinent to land use and BS4142:2014 Method for rating and assessing industrial and commercial sound.

4.7 The weather during the survey was a mix of rain with light winds, the conditions were suitable for the measurement of environmental noise. Wind had no set direction throughout the test and speeds did not exceed (<5m/s), cloud cover varied throughout testing.

4.8 The noise monitoring equipment used was calibrated before and after both the noise survey periods. No significant drift was recorded for either. Equipment calibration certificates can be provided upon request.

4.9 The survey equipment was not positioned directly at site but at number 8 Silver Street. This position can be considered to represent the environmental noise at the site given there is only approximately 5m difference.

5. Uncertainty

5.1 All measurements onsite were taken with a sound level meter manufacturer's margin of uncertainty at typically +/- 1.1dB. It is due to the tolerances associated with Class 1 sound level meters and calibrator equipment used to measure background noise.

6. Results

6.1 The section below gives the Baseline Noise Survey readings taken at site.

Date	Time Period	Sound Pressure Level dB (L _{Aeq})	Sound Pressure Level dB (L ₉₀)
13/11/25 Thursday	Daytime (07:00-23:00hrs)	59dB	51dB
	Nighttime (23:00-07:00hrs)	51dB	46dB
14/11/25 Friday	Daytime (07:00-23:00hrs)	60dB	55dB
	Nighttime (23:00-23:00hrs)	55dB	41dB
15/11/25 Saturday	Daytime (07:00-19:00hrs)	59dB	53dB
	Nighttime (23:00-23:00hrs)	61dB	53dB
16/11/25 Sunday	Daytime (07:00-23:00hrs)	59dB	53dB
	Nighttime (23:00-07:00hrs)	54dB	50dB

6.2 This table gives an averaged final single figure decibel rating at the site.

Date	Time Period	Sound Pressure Level dB (L _{Aeq})	Sound Pressure Level dB (L ₉₀)
13/11/25- 16/11/25	Daytime (07:00-23:00hrs)	59dB	53dB
	Nighttime (23:00-07:00hrs)	57dB	48dB

6.3 The average ambient (L_{Aeq}) noise levels at the measurement position during the survey has been based on an analysis of the monitored data.

7. Assessment of noise breakout

7.1 Noise levels from takeaways vary depending on size and how busy they are. From previous surveys undertaken a busy takeaway at peak times has an overall 72dB(A) 5min at a peak time, based upon the internal levels indicated above, the typical "in-to-out" level difference would be.

Noise type and distance nearest site window	Combined sound pressure of air handling and heat source	Barrier attenuation	Noise at position after distance propagation correction & screening dB(A)
Takeaway (3m)	72dB dB(A)	-25dB (standard single glazing)	37

7.2 In accordance with the approach outlined in the IEMA document, the predicted and the measured levels have been used to calculate the possible increase of the noise climate at the assessed receptors. For this purpose, the minimum measured L_{Aeq}, 15 min and the predicted L_{Aeq} have been combined. We understand that potential annoyance caused by noise break-out can be higher than any other type of noise,

since it also contains words that can increase the subjective audibility. Because of this reason, we have applied a penalty correction of +5dBA to every predicted value.

7.3 The increase of the existing noise climate due to noise break-out from the proposed restaurant is calculated below.

- Daytime

Scenario	Predicted LAeq at receiver	Attenuation	Correction (dBA)	Corrected noise level at receiver (dBA)	Existing noise Leq	Overall Predicted LAeq (dB)	Change in existing Noise Climate
Takeaway (3m)	72dB dB(A)	-25dB (standard single glazing)	5	42	59	59	0

- Nighttime

Scenario	Predicted LAeq at receiver	Attenuation	Correction (dBA)	Corrected noise level at receiver (dBA)	Existing noise Leq	Overall Predicted LAeq (dB)	Change in existing Noise Climate
Takeaway (3m)	72dB dB(A)	-25dB (standard single glazing)	5	42	57	57	0

8. Assessment of extraction noise

8.1 It is currently not known whether a full extraction system will be installed however, for the purposes of this report, an assessment of extraction has been undertaken with limits of noise.

8.2 Should extraction be fitted, it will be require to be vented at roof height.

8.3 When calculating the sound power levels it should be at the termination of the ventilation duct run taking into account the following:

- sound power of the fan
- length of type of duct
- silencer insertion loss
- bends
- end reflection


8.4 The document is not designing the duct work but giving a "limit of noise" produced.

Time	L90 measured at site	Character correction BS4142	Requirements	Limit of sound LAeq
Daytime	53dB(dBA)	+5dB	5dB below background noise	43(dBA) (daytime)
Nighttime	48dB(dBA)	+5dB	5dB below background noise	38(dBA) (daytime)

9. Assessment of Partition from commercial to residential

9.1 The separation of the commercial space from the residential space is recommended to achieve an enhancement above the building regulations minimum levels. Particular attention should be given to construction makeup of areas that are considered noisy such as bars and gyms to minimise structure-borne noise transfer and airborne noise control measures such as sound insulation materials.

9.2 Exact current levels of attenuation are unknown therefore it is advised to increase the acoustic attenuation levels using a proven make up that assumes a minimal existing level, the below Hush acoustic system is specifically designed to improve levels from the floor below where access to the floor above is not possible.



10. Conclusion

10.1 Measurements have been made of the prevailing noise climate at 4-6 Silver Street, Bury, OL9 0EX.

10.2 The assessment outlined national and local guidance and considers this in relation to the likely operational activity and use of the building.

10.3 The assessment outlined national and local guidance and considers this in relation to the likely operational activity and use of the building and in compliance with BS8233:2014, BS 4142: 2014+A1:2019 & BS 7445.

10.4 The results of the predictions have demonstrated that noise break-out from the premises will have no impact on the prevailing noise levels at the worst affected residential property.

10.5 Limit of noise for extraction has been calculated at the nearest noise sensitive receptors.

10.6 Given the assessment undertaken, it is considered that a good level of residential amenity will be provided for residents and that the noise impacts associated with the development can be controlled to an acceptable level now and in the future.



Andrew Hunt
TechIOA

Appendices

A. These are the main noise indices in use in the UK.

- dB(A): The human ear does not hear all frequencies with the same intensity. It is most sensitive to sounds in the 500Hz-8kHz range. Above and below this range the ear becomes progressively less sensitive. To compensate for this, sound level meters incorporate electronic filtering to correspond with the varying sensitivity of the ear. This filtering is called A-weighting and Sound Pressure Levels obtained with this weighting are referred to as A-weighted and signified as dB(A).
- LA90: The sound level (in dBA) exceeded for 90% of the time. This unit gives an indication of the sound level during the quieter periods of time in any given sample. It is used to describe the "background noise level" of an area.
- LAeq,T: The equivalent continuous sound pressure level over a period of time, T; (in dBA) This unit may be described as "the notional steady noise level that would provide, over a period, the same energy as the varying noise in question". In other words, the energy average level. This unit is now used to measure a wide variety of different types of noise of an industrial or commercial nature, as well as road traffic, aircraft and trains.
- LA1: The sound pressure level (in dBA) exceeded for 1% of the time. This unit can give an indication of a regular maximum noise level from such activities as dance music.
- LAe: The sound exposure level, (previously denoted SEL) is the noise level of an event, such as a train or aircraft event, normally expressed in a 1 second time period.
- LAmin: The minimum sound pressure level (in dBA) measured over the time period.
- LAmax: The maximum level of sound (in dBA), i.e. the peak level of sound measured in any given period. This unit is used to measure and assess transient noises, i.e. gun shots, individual vehicles, etc.
- LArT: sound rating level, the a-weighted, leq sound level of an industrial noise during a specified time period, adjusted for tonal character and impulsiveness.

B. Results

	LAeq	L90
16:03	55.1	50.9
16:18	58.1	51.4
16:33	57.5	51.9
16:48	56.8	51.9
17:03	57.9	51.2

17:18	58.9	52.9
17:33	58	53.2
17:48	58.9	53.2
18:03	59.9	53
18:18	61.4	52.4
18:33	59.3	52.3

18:48	59.4	53.1
19:03	59.9	52.4
19:18	59.3	52.6
14:45	59.9	52.7
15:00	59	52.4
15:15	60	51.1

15:30	60.2	52.1
15:45	60.7	52.8
16:00	59.8	52.8
16:15	60.3	54.1
16:30	61.8	53.5
16:45	59.6	52.8
17:00	63.6	53.7
17:15	59.7	54.7
17:30	59.9	54.6
17:45	60.2	53.9
18:00	62.2	56.9
18:15	62.6	56.9
18:30	61.2	55.1
18:45	63.8	52.5
19:00	59.1	52.6
19:15	59.3	51.7
19:30	58.9	49.9
19:45	57.5	50.1
20:00	58.3	50.5
20:15	57.2	49.8
20:30	56.5	48.1
20:45	56.1	47
21:00	57	46.8
21:15	55.1	48.1
21:30	54.7	47.6
21:45	55.5	47.2
22:00	55.6	45.8
22:15	54.8	46.3
22:30	54.8	47.2
22:45	53.6	46.5
23:00	53.8	45.7
23:15	53.7	45.4
23:30	52.7	44.1
23:45	52.3	43.6
00:00	49.1	41.5
00:15	52.1	42.7
00:30	56.7	41.9
00:45	50.1	41.2
01:00	46.9	41.6
01:15	49.1	41.4
01:30	44.4	41.2
01:45	45.2	41.5
02:00	44.6	41.3
02:15	44.3	41.4
02:30	44.6	41.8
02:45	43	42.1

03:00	43.4	42
03:15	47.8	46.4
03:30	47.8	46.6
03:45	48	47
04:00	49.6	46.6
04:15	49.1	47.6
04:30	49.2	47.9
04:45	50.3	48.9
05:00	53.4	49.5
05:15	53.9	49.8
05:30	55.3	50.5
05:45	53.5	50.9
06:00	55.5	51.4
06:15	57.9	52.7
06:30	58.4	53.6
06:45	60.5	54.6
07:00	61.3	56.4
07:15	61.6	56.8
07:30	63.2	57.5
07:45	62.8	58.2
08:00	62.8	57.4
08:15	64.4	57.6
08:30	62.1	56.3
08:45	60.9	56.6
09:00	61.8	57.6
09:15	61.3	56.9
09:30	61.2	57.4
09:45	60.1	56.5
10:00	63.3	55.7
10:15	60.8	56.8
10:30	59.9	55.8
10:45	60.9	55.9
11:00	63.8	56
11:15	60.5	56.4
11:30	59.8	56.3
11:45	59.8	56
12:00	59.2	55.8
12:15	59.3	56
12:30	59.6	56
12:45	59.9	56.8
13:00	60.6	56.4
13:15	59.1	55.1
13:30	62.3	54.9
13:45	59.8	55.1
14:00	59.2	55.4
14:15	59.6	55.3

14:30	59.7	55.8
14:45	60.2	56.5
15:00	59.4	55.8
15:15	60.4	56.3
15:30	60.8	56.8
15:45	61.5	56.1
16:00	63.5	56.2
16:15	61.6	56.7
16:30	61	56.5
16:45	59.8	55.7
17:00	60.8	56.8
17:15	60.8	57.2
17:30	61.3	57.2
17:45	59.8	55.8
18:00	59.6	55.9
18:15	59.3	55.4
18:30	59.4	55.6
18:45	58.9	55.3
19:00	60.8	56
19:15	60	55.5
19:30	60.4	55.2
19:45	62.4	56.4
20:00	60.3	54.7
20:15	60	53.6
20:30	58.5	52.3
20:45	60	53.9
21:00	59.6	52.8
21:15	58.8	51.9
21:30	60.3	53
21:45	60	53.5
22:00	60	53.4
22:15	60.5	53.7
22:30	61.4	53.3
22:45	58.4	52
23:00	62.3	57.4
23:15	64	57.8
23:30	63.2	57.5
23:45	62.4	57.5
00:00	63.8	56.7
00:15	62	56.1
00:30	60	55.2
00:45	63.3	55.5
01:00	62.1	56.1
01:15	61.4	56.1
01:30	62.2	54.4
01:45	57.9	53.5

02:00	57.6	54
02:15	58.6	54.7
02:30	59.4	53.4
02:45	55.1	51.2
03:00	62.5	50.5
03:15	57.5	51
03:30	58.1	52
03:45	58.8	54.6
04:00	59.9	56.4
04:15	59.9	52.5
04:30	58.1	52.8
04:45	53.2	47.1
05:00	54.9	51.7
05:15	53	48.2
05:30	56.2	49.3
05:45	55.6	49.7
06:00	54.6	47
06:15	56.4	49.1
06:30	54.4	49.4
06:45	56.3	49.6
07:00	56.5	50.1
07:15	57.1	51.7
07:30	59.7	53.2
07:45	60.8	54.7
08:00	64.2	53.4
08:15	61.7	52.8
08:30	60.8	55.1
08:45	60.9	55.3
09:00	60	54.4
09:15	58.8	53
09:30	62.1	53.7
09:45	58.2	51.2
10:00	58	51.8
10:15	58.4	51.7
10:30	60.7	52.7
10:45	58.5	52
11:00	59.1	53.4
11:15	59.3	53.8
11:30	58.9	53.2
11:45	60.5	54.4
12:00	60.7	55.5
12:15	58.9	53.4
12:30	58.9	53.4
12:45	59	53.2
13:00	58.6	53.3
13:15	62.6	52.9

13:30	58.5	52.3
13:45	58.3	53.3
14:00	59.8	53.7
14:15	61.4	54.9
14:30	61.2	54.8
14:45	61.4	54.8
15:00	62.3	54.3
15:15	59.7	53.9
15:30	60.6	54.5
15:45	60.8	54.2
16:00	61.7	55.7
16:15	60.8	54
16:30	63.7	55.4
16:45	61.8	55.2
17:00	66	56.7
17:15	62.7	58.6
17:30	62.7	56.4
17:45	62.4	56.5
18:00	61.7	55.6
18:15	61.7	56
18:30	62.4	56.6
18:45	61.1	54.8
19:00	60.3	53.7
19:15	60.9	54.1
19:30	60.4	54.1
19:45	60.3	53.8
20:00	59.2	53.2
20:15	60	53.6
20:30	65	52.3
20:45	58	51.4
21:00	58.2	51.4
21:15	59.4	51.9
21:30	57.3	51.1
21:45	57.3	50.8
22:00	57.9	50.7
22:15	58.4	51.3
22:30	59.6	51.4
22:45	56.8	48.5
23:00	62.2	55.6
23:15	62.5	55
23:30	62.4	55.7
23:45	61.1	55.4
00:00	65.4	55.3
00:15	63.2	54.5
00:30	61.6	56.8
00:45	62.1	55.6

01:00	64.5	56.3
01:15	64.5	55.9
01:30	62.7	56.6
01:45	65.9	58.6
02:00	61.6	55.7
02:15	62.2	54.5
02:30	60.6	54.6
02:45	58.7	52.3
03:00	62.6	53.6
03:15	64.2	53.2
03:30	59.5	48.5
03:45	58	47.2
04:00	51.8	46.9
04:15	49.8	47.7
04:30	57.9	48.9
04:45	53.4	49.1
05:00	57.5	51
05:15	60.9	51.6
05:30	61.4	52.6
05:45	58.7	53.2
06:00	58.8	53.2
06:15	63.1	54.6
06:30	60.3	55.4
06:45	66.4	56.9
07:00	56.4	50.9
07:15	56.8	51
07:30	59.1	53.5
07:45	60.5	54
08:00	59.8	53.8
08:15	59.2	53.8
08:30	62.8	53.4
08:45	62.6	55.4
09:00	59.8	54.2
09:15	59.2	52.2
09:30	58.6	52.5
09:45	58.3	52.2
10:00	59.5	52.1
10:15	59.3	52
10:30	57.5	52
10:45	60.1	52.8
11:00	58.2	52
11:15	57.8	52.6
11:30	58.1	52.7
11:45	57.7	51.7
12:00	59.7	54.5
12:15	57.9	52.4

12:30	57.9	52.4
12:45	58	52.2
13:00	57.6	52.3
13:15	61.6	51.9
13:30	57.5	51.3
13:45	57.3	52.3
14:00	58.8	52.7
14:15	60.4	53.9
14:30	60.2	53.8
14:45	60.4	53.8
15:00	61.3	53.3
15:15	58.7	52.9
15:30	59.6	53.5
15:45	59.8	53.2
16:00	60.7	54.7
16:15	59.8	53
16:30	62.7	54.4
16:45	60.8	54.2
17:00	65	55.7
17:15	61.7	57.6
17:30	61.7	55.4
17:45	61.4	55.5
18:00	60.7	54.6
18:15	60.7	55
18:30	61.4	55.6

18:45	60.1	53.8
19:00	59.3	52.7
19:15	59.9	53.1
19:30	59.4	53.1
19:45	59.3	52.8
20:00	58.2	52.2
20:15	59	52.6
20:30	64	51.3
20:45	57	50.4
21:00	57.2	50.4
21:15	58.4	50.9
21:30	56.3	50.1
21:45	56.3	49.8
22:00	56.9	49.7
22:15	57.4	50.3
22:30	58.6	50.4
22:45	55.8	47.5
23:00	55.2	48.6
23:15	55.8	48.3
23:30	55.7	49
23:45	54.4	48.7
00:00	58.7	48.6
00:15	56.5	47.8
00:30	54.9	50.1
00:45	55.4	48.9

01:00	57.8	49.6
01:15	57.8	49.2
01:30	56	49.9
01:45	59.2	51.9
02:00	54.9	49
02:15	55.5	47.8
02:30	53.9	47.9
02:45	52	45.6
03:00	55.9	46.9
03:15	57.5	46.5
03:30	52.8	41.8
03:45	51.3	40.5
04:00	45.1	40.2
04:15	43.1	41
04:30	51.2	42.2
04:45	46.7	42.4
05:00	50.8	44.3
05:15	54.2	44.9
05:30	54.7	45.9
05:45	52	46.5
06:00	52.1	46.5
06:15	56.4	47.9
06:30	53.6	48.7
06:45	59.7	50.2
07:00	55.7	50.2

004

4

OP6 Shared WC

OP5 Shared Staff Room 9.2 m²

OP7 Residential Entrance

Electrical Dis.

OP4 Kitchen 9.4 m²

OP1 Hot Food Takeaway 14.7 m²

OP2 Hot Food Takeaway 32.3 m²

OP3 Kitchen 18.3 m²

Service Counter

SE - To Open as wide as possible

Storage

OP8 Hot Surfaces

Glass Minder

4188

4748

3252

1839