

69827 | Installation of a prescription collection automated dispenser | 6 Vernon Road, Tottington, Bury, BL8 4DD

Thank you for the opportunity to comment on the above application. The following measures are considered essential to secure the vending machine, as well as protect its users/replenishers and it is recommended that they are conditioned as part of any approval:

- Lighting should be provided to the area around the proposed vending machine to an adequate and uniform level, so as not to allow any areas of pooling/shadowing.
- Defensible space ground markings (e.g. 1m² painted area, change in surface texture, metal studs within paving etc.) should be employed and maintained at the front of the vending machine to indicate that only one user at a time may enter the space.
- The proposed vending machine should be protected by a closed circuit television system that should view the area and the users of the vending machine.
- Risk assessments should be undertaken for the replenishment of the vending machine.

In summary, it is essential that the above matters are addressed in order to gain our full support for proposal.

Designing Out Crime Officer (DOCO)
Assistant Design For Security Consultant