

Reference No: ECH/6137.22

F.A.O Michael/Paul
Elnecot Restaurant
449A Bury New Road
Prestwich
Manchester
M25 1AF

7th February 2022

Dear Sirs,

Reference: Ductwork to Canopy

Further to my site visit, I have pleasure enclosing a quotation and installation information for the above project. The details of which are outlined below. We would offer to carry out the following works.

As DEFRA 2005 and 2010 has now been withdrawn, we are referring to this in conjunction with the 2018 edition of DW/172 Section 24 for odour control recommendation. We can confirm that the ESP Odour control system is designed to capture grease and smoke particulates (DW/172 24.6) and use UV in the reduction of odours (DW/172 24.7). This is in accordance with DEFRA 2005: Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems and DW/177 BESA Specification for Kitchen Ventilation System.

Canopy Ductwork

We would offer to install 1 No 315 heavy duty Axial fan complete with 2 No Silencers and 1 No ESP (Electro static Participator Filter box) the ductwork would run from the canopy to the outside then fix up the exterior wall finishing with a Jet Cowl above the roof level.

