

From: Scott, Judith

Sent: 28 November 2022 13:59

To: Clapworthy, Dean <D.Clapworthy@bury.gov.uk>; Jones, Rebecca <Rebecca.Jones@bury.gov.uk>

Subject: RE: 67953: 24 Brookfield - Demolition of existing link detached dwelling and erection of 2 no. semi-detached dwellings

Hi Dean

I've attached our previous response.

We are no longer recommending the EV charging condition as it is covered by Building Regs so this could be swapped for the below:

EV Charging provision – COMMENT

Bury Council has been identified by DEFRA as an area requiring to significantly improve air quality. The required measures to do this are currently under discussion. Due to this requirement, and the requirements of the new building regulations (The Building Regulations 2010, Approved Document S, Infrastructure for the charging of electric vehicles), please supply details of the proposed provision for electric vehicle charging.

Let me know if you require anything further.

Thank you

Regards

Judith Scott

Environmental Protection Officer

Department of Operations



Follow us on

