

It is recommended that any new doorsets to be installed are security-certified to BS PAS 24, LPS 1175 SR2 or STS 202 BR2, any new windows are security-certified to BS PAS 24 and any new glazing includes a laminated pane rated as P4A under EN 356, in order to protect the premises from unauthorised access and damage.

Design for Security Consultant

for and on behalf of Greater Manchester Police | Crime Prevention Team

design**forsecurity** | prevent**andsecure**