



This document and its contents are the property of the
Partnership and are not to be copied or reproduced in any way, in part or whole, without prior written
approval of the Partnership. The drawing shall be read in conjunction with the CWC Mechanical and
or Electrical Specifications.
DO NOT SCALE FROM THIS DRAWING

DESIGNERS RISK ASSESSMENT
REFER TO APPENDIX 1 OF M&E SPECIFICATION FOR
DESIGNERS RISK ASSESSMENT SCHEDULE

DRAWING BACKGROUNDS:

COMPANY	DRAWING NUMBER	REV
JHA	BURNAR-JHA-V2-ZZ-DR-E-6301	P20

NOTES

- DO NOT SCALE OFF THIS DRAWING.
- ALL ELECTRICAL EQUIPMENT SHALL BE DESIGNED
INSTALLED TESTED AND COMMISSIONED IN LINE
WITH THE REQUIREMENTS OF BS7671.
- THIS DRAWING REPRESENTS DESIGN INTENT ONLY
AND SHALL NOT BE USED FOR INSTALLATION
PURPOSES.
- ALL MARKET CANOPY LIGHTING TO BE SUSPENDED
FROM STRUCTURAL STEEL AT HIGH LEVEL.
- ALL LIGHTING LEVELS AND UNIFORMITY
CALCULATIONS SHALL BE PROVIDED BY THE
CONTRACTOR FOR REVIEW DURING STAGE 4
- REFER TO SPECIFICATION FOR EXTERNAL
LIGHTING CONTROL PHILOSOPHY
- CONTRACTOR TO INCLUDE FOR AND DEVELOP THE
PUBLIC REALM EXTERNAL LIGHTING CONTROL
STRATEGY UTILIZING PHILIPS LIGHTING CITY
TOUCH LIGHTING CONTROL SYSTEM DURING
STAGE 4

LEGEND

- WHITECROFT LIGHTING - ECHO 280 LED
(EC280-H404K + EC30)
- EMERGENCY VERSION OF ABOVE
- EXTERNAL LIGHTING TM COLUMN ESCOFET BALI
- EXTERNAL LIGHTING BUILDING MOUNTED
EMERGENCY BULKHEAD AS WHITECROFT
CONCRETE EDGE
- EXTERNAL LIGHTING BUILDING MOUNTED ESCOFET
BALI
- RECESSED EXTERNAL DOWN LIGHTERS, AS
WHITECROFT MIRAGE LED IP65
- EMERGENCY MAINTAINED DIRECTIONAL
SIGNAGE

Rev	Date	Description	CB	BU
P2	17/02/23	STAGE 3 ISSUE	CB	BU
P1	16/09/22	PRELIMINARY	TW	BU
Rev	Date	Description	Eng	Chg

CWC
CROOKS WATKINS
CONSULTING

Scale: As Shown: 1:750
Manchester M2 3AW
Tel: 0161 634 9999
The Plaza, Old Hall Street,
Liverpool L3 9JL
Tel: 0151 634 9449
50 Colmore Row, Birmingham B3 2AA
Tel: 0121 262 4046
E-mail: admin@cwcon.co.uk
Website: www.cwcon.co.uk

Client

VINCI

Project

**BURY MARKET
AND
FLEXI HALL**

Drawing Title

**MARKET CANOPY GENERAL
AND EMERGENCY LIGHTING
LAYOUTS**

Status

STAGE 3

Project No.	Drawn	Scale / Paper Size
2451	TW	1:200 @ A0

Drawing No.	Rev
BURNAR-CWC-V2-ZZ-DR-E-6301	P2