

EH comment

A suitable noise assessment to be carried out, conducted in accordance With Microgeneration Installation standard MCS 020, to confirm whether the permitted development noise limit of 42dBlaeq 5 mins would be met. The assessment must demonstrate that the introduction of the heat pump is going to meet the standard.

thanks

Unit Manager, Commercial Team
Bury Council | Department for Operations | Public Protection
3 Knowsley Place | Duke Street | Bury | BL9 0EJ