

Apartments NDSS Report												23036-PJA-AP-XX-SH-A-9500.
Apartments			Master bed			Bedroom 2				Overall Storage		Comments
Apartment No.	NDSS req. area (m2)	GIA (m2)	DIMS (m)	AREA (m2)	NDSS	Type	DIMS (m)	AREA (m2)	NDSS	AREA (m2)	NDSS	
Lower Ground Floor												
L101, L102,L104,L105 (1B2P)	1B2P 50	54	5.4x3.1	16.7	Yes	-	-	-	-	3.6	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
L103, L106 (2B3P)	2B3P 61	64	4.3x3.5	14.7	Yes	single	10.32	10.4	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
Ground Floor												
001, 002, 004, 005, 007, 008, 009, 0010, 0011, 0013, 0014 (1B2P)	1B2P 50	54	5.4x3.1	16.7	Yes	-	-	-	-	3.6	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
003, 006, 0012 (2B3P)	2B3P 61	64	4.3x3.5	14.7	Yes	single	10.32	10.4	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
First Floor												
0101, 0102, 0106, 0107, 0108, 0109, 01011, 01012, 01013, 01014, 01016, 01017 (1B2P)	1B2P 50	54	5.4x3.1	16.7	Yes	-	-	-	-	3.6	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
0103, 0104, 01010, 01015,(2B3P)	2B3P 61	64	4.3x3.5	14.7	Yes	single	10.32	10.4	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
0105 (2B3P)	2B 3P 61	67	5.2x2.8	15.0	Yes	single	3.8x2.6	9.8	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
Second Floor												
0201, 0202, 0206, 0207, 0208, 0209, 02011, 02012, 02013, 02014, 02016, 02017 (1B2P)	1B2P 50	54	5.4x3.1	16.7	Yes	-	-	-	-	3.6	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
0203, 0204, 02010, 02015,(2B3P)	2B3P 61	64	4.3x3.5	14.7	Yes	single	10.32	10.4	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
0205 (2B3P)	2B 3P 61	67	5.2x2.8	15.0	Yes	single	3.8x2.6	9.8	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
Third Floor												
0301, 0304, 0306 (1B2P)	1B2P 50	54	5.4x3.1	16.7	Yes	-	-	-	-	3.6	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
0302, 0305 (2B3P)	2B3P 61	64	4.3x3.5	14.7	Yes	single	10.32	10.4	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements
0303 (2B3P)	2B 3P 61	67	5.2x2.8	15.0	Yes	single	3.8x2.6	9.8	Yes	2.7	Yes	Overall GIA is above NDSS requirement. Storage exceeds NDSS requirement. Apartment type meets NDSS requirements

Note: Dims 9m0 refers to evidencing minimum widths as per NDSS Section 10, Technical Requirements. Actual room areas have been accurately calculated, accounting for irregularly shaped spaces rather than solely relying on the minimum widths provide