

This document and its contents are the property of the Purchaser/Employer and Crookes Walker Consulting. They may not be copied or reproduced in any way, in part or whole, without prior written approval of both parties. Violations will result in legal action. This drawing shall be read in conjunction with the CWC Mechanical and / or Electrical Specification(s). DO NOT SCALE FROM THIS DRAWING

DESIGNERS RISK ASSESSMENT SCHEDULE
REFER TO APPENDIX 1 OF M&E SPECIFICATION FOR DESIGNERS RISK ASSESSMENT SCHEDULE

DRAWING BACKGROUND(S):

LEGEND

- EA - EXTRACT AIR
SA - SUPPLY AIR
REFRIGERATION PIPEWORK TRAY
AHU MAINTENANCE ZONE
SAFE ACCESS ROUTE
CONDENSER ATTENUATOR

MVHR - MECHANICAL VENTILATION HEAT RECOVERY

FCU- FAN COIL UNIT

AHU- AIR HANDLING UNIT

SFD- SMOKE FIRE DAMPER

ATT- ATTENUATOR

NOTES:

1. ALL PLANT SHALL BE SUPPORTED ON BIG FOOT TYPE SUPPORT FRAMES MIN 300MM ABOVE ROOF LEVEL
2. ALL EXTERNAL DUCTWORK SHALL BE THERMALLY INSULATED, VAPOUR SEALED AND WEATHER CLAD (SELF ADHESIVE MEMBRANE)

P5	20.03.23	ROOF PLANTROOM REDESIGN	AM	RW
P4	22.02.23	STAGE 3 REDESIGN	AM	RW
P3	17.02.23	STAGE 3 REDESIGN	AM	RW
P2	16.09.22	PRELIMINARY	AM	RW
P1	09.08.22	PRELIMINARY	AM	RW
Rev	Date	Description	Eng	CHK

CWC
crookes walker consulting

Suite 9a, Bloc, 17 Marble Street
Manchester M2 3AW
Tel: 0161 834 9999
The Plaza, Old Hall Street,
Liverpool L3 9QJ
Tel: 0151 600 5409
55 Colmore Row, Birmingham B3 2AA
Tel: 0121 262 4046
E-mail: admin@cwcon.co.uk
Website: www.cwcon.co.uk

Client

VINCI

Project
BURY MARKET AND FLEXI HALL

Drawing Title
ROOF LEVEL VENTILATION LAYOUT

Status
STAGE 3

Project No. 2451	Drawn AM	Scale / Paper Size 1 : 100 @ A1
----------------------------	--------------------	---

Drawing No. BURMAR-CWC-V2-04-DR-M-5701	Rev P5
--	------------------

