



The Coal
Authority



INVESTOR IN PEOPLE



RTPI

Learning Partner

200 Lichfield Lane
Berry Hill
Mansfield
Nottinghamshire
NG18 4RG

Tel: 01623 637 119 (Planning Enquiries)

Email: planningconsultation@coal.gov.uk

Web: www.gov.uk/coalauthority

For the Attention of: Helen Leach – Case Officer
Bury Metropolitan Borough Council

[By Email: development.control@bury.gov.uk]

15 November 2023

Dear Helen

PLANNING APPLICATION: 70195

Erection of an extension to contain classrooms, multi- purpose hall and support areas; landscaping works to include dedicated play areas, railings and external pagoda and additional car parking on the existing school site; Millwood Primary Special School, School Street, Radcliffe, Manchester, M26 3BW

Thank you for your consultation letter of 26 October 2023 seeking the views of the Coal Authority on the above planning application.

The Coal Authority is a non-departmental public body sponsored by the Department for Energy Security and Net Zero. As a statutory consultee, the Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority Response: Material Consideration

I have reviewed the proposals and can confirm that the site falls within the defined Development High Risk Area.

The Coal Authority records indicate the site is likely affected by probable shallow coalmine workings. Voids and broken ground associated with such workings can pose a risk of ground instability and may give rise to the emission of mine gases.

The applicant has obtained appropriate and up-to-date geological and mining information, as well information from the results of intrusive site investigations undertaken. This has been used to inform the Shallow Coal Mining Site Investigation Works Report (September

2023, prepared by LK Group), which accompanies the planning application. From a review of the site investigations undertaken, the Report confirms that an intact coal seam was encountered, but with insufficient competent rock cover above it to afford ground stability, specifically in the event of it being worked. Consequently, the Report confirms that a proof drilling and grouting operation is required.

The applicant should note that Permission is required from the Coal Authority Permit and Licensing Team before undertaking any activity, such as ground investigation and ground works, which may disturb coal property. Please note that any comments that the Coal Authority may have made in a Planning context are without prejudice to the outcomes of a Permit application.

Mine Gas

It should be noted that wherever coal resources or coal mine features exist at shallow depth or at the surface, there is the potential for mine gases to exist. These risks should always be considered by the LPA. The Planning & Development team at the Coal Authority, in its role of statutory consultee in the planning process, only comments on gas issues if our data indicates that gas emissions have been recorded on the site. However, the absence of such a comment should not be interpreted to imply that there are no gas risks present. Whether or not specific emissions have been noted by the Coal Authority, local planning authorities should seek their own technical advice on.

SUDS

It should be noted that where SUDs are proposed as part of the development scheme consideration will need to be given to the implications of this in relation to the stability and public safety risks posed by coal mining legacy. The developer should seek their own advice from a technically competent person to ensure that a proper assessment has been made of the potential interaction between hydrology, the proposed drainage system and ground stability, including the implications this may have for any mine workings which may be present beneath the site.

The Coal Authority Recommendation to the LPA

The Coal Authority concurs with the recommendations of the Shallow Coal Mining Site Investigation Works Report (September 2023, prepared by LK Group) that shallow coalmine workings pose a risk to the proposed development and that remediation should be undertaken prior to development.

Accordingly, the Coal Authority recommends the imposition of the following conditions:

1. *No development shall commence until;*

a) any remediation works and/or mitigation measures to address the shallow mine workings, as may be necessary, have been implemented on site in full in order to ensure that the site is safe and stable for the development proposed.

The intrusive site investigations and remedial works shall be carried out in accordance with authoritative UK guidance.

2. *Prior to the occupation of the development, or it being taken into beneficial use, a signed statement or declaration prepared by a suitably competent person confirming that the site is, or has been made, safe and stable for the approved development shall be submitted to the Local Planning Authority for approval in writing. This document shall confirm the methods and findings of the intrusive site investigations and the completion of any remedial works and/or mitigation necessary to address the risks posed by the recorded mine entry.*

The Coal Authority therefore **has no objection** to the proposed development **subject to the imposition of the conditions to secure the above**. *This is our recommendation for condition wording. Whilst we appreciate that you may wish to make some amendment to the choice of words, we would respectfully request that the specific parameters to be satisfied are not altered by any changes that may be made.*

The following statement provides the justification why the Coal Authority considers that a pre-commencement condition is required in this instance:

The undertaking of remedial measures, prior to the commencement of development, is considered to be necessary. This is in order to ensure the safety and stability of the development, in accordance with paragraphs 183 and 184 of the National Planning Policy Framework.

**PLEASE INCLUDE AS INFORMATIVE NOTES FOR APPLICANTS ON ANY
PLANNING PERMISSION GRANTED**

1 – Ground Investigations

Under the Coal Industry Act 1994 any intrusive activities, including initial site investigation boreholes, and/or any subsequent treatment of coal mine workings/coal mine entries for ground stability purposes require the prior written permission of The Coal Authority, since such activities can have serious public health and safety implications. Failure to obtain permission to enter or disturb our property will result in the potential for court action. In the event that you are proposing to undertake such work in the Forest of Dean local authority area our permission may not be required; it is recommended that you check with us prior to commencing any works. Application forms for Coal Authority permission and further guidance can be obtained from The Coal Authority's website at: www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Chris MacArthur

Chris MacArthur *B.Sc.(Hons), DipTP, MRTPI*
Planning Liaison Manager

General Information for the Applicant

Under the Coal Industry Act 1994 any intrusive activities, including initial site investigation boreholes, and/or any subsequent treatment of coal mine workings/coal mine entries for ground stability purposes require the prior written permission of The Coal Authority, since such activities can have serious public health and safety implications. Failure to obtain permission will result in trespass, with the potential for court action. In the event that you are proposing to undertake such work in the Forest of Dean local authority area our permission may not be required; it is recommended that you check with us prior to commencing any works. Application forms for Coal Authority permission and further guidance can be obtained from The Coal Authority's website at:

<https://www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property>

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.

In formulating this response The Coal Authority has taken full account of the professional conclusions reached by the competent person who has prepared the Coal Mining Risk Assessment or other similar report. In the event that any future claim for liability arises in relation to this development The Coal Authority will take full account of the views, conclusions and mitigation previously expressed by the professional advisers for this development in relation to ground conditions and the acceptability of development.