

**71345**

What are the types of business that could use these units? The noise report states light industrial for the storage of tools and materials.

The noise assessment has identified a significant adverse impact on the nearest sensitive receptors. Therefore, mitigation is required, and this must be a condition as part of the build and the working hours once in operation. The report states that mitigation should be:

- The operational hours should not exceed 08:00 – 17:00 Monday to Friday.
- All doors and or shutters should remain closed during operational hours.
- Upgrade the shed panelling to provide a minimum sound reduction of 40 dB Rw. An example of adequate solution can be a pre-finished steel cladding system from TATA STEEL. See technical data within Appendix F of the noise report.

thanks

Rob Hall

Unit Manager, Commercial Team

Bury Council | Department for Operations | Public Protection

3 Knowsley Place | Duke Street | Bury | BL9 0EJ