

71419

The noise assessment report (point 5, pg 6 to 5.1.2.1 pg 8) has proposed mitigation to acoustically line the party wall of no.72 and no.70 with Hush-Wall lining which has been calculated to achieve 50dB reduction. This must be a condition of the application.

thanks

Rob Hall

Unit Manager, Commercial Team

Bury Council | Department for Operations | Public Protection

3 Knowsley Place | Duke Street | Bury | BL9 0EJ