

71405

EH comments:

Traffic noise – windows: soundproofing/insulation

No development shall take place unless and until a scheme to soundproof the building/windows against traffic noise has been submitted to and approved by the Local Planning Authority so as to achieve an internal level of L10 40dBA (18 hour)* and such works that form the approved scheme shall be completed before the relevant HMO is brought into use.

** The Noise Insulation Regulations 1975 as amended by the 1988 Regulations*

Reason

To ensure that the development is adequately soundproofed against externally generated noise in the interests of the amenity of future occupiers of the development

thanks

Rob Hall

Unit Manager, Commercial Team

Bury Council | Department for Operations | Public Protection

3 Knowsley Place | Duke Street | Bury | BL9 0EJ