

70789 – Pollution Control response

The site of this proposed development is situated in an area surrounded by industrial activities.

It is likely that noise disturbances will occur to any residents of this proposed development from activities carried out on these adjacent sites or that may be carried out in the future, especially if these activities occur late at night or early in the morning.

The noise assessment does not contain any measurements of ambient noise in the area and how this will affect the residents of the proposed application.

Therefore we believe that A suitable noise investigation shall be conducted to the satisfaction of the Local Planning Authority (LPA) to determine the suitability of the site for the proposed development. This would include noise measurements and recommendations for mitigation of noise if it is necessary.