

**FLUE SPECIFICATION FOR WORKS TO CUCKOO
RESTAURANT, 395-399 BURY NEW ROAD,
SEPTEMBER 2024**

Work required:

New 500 mm diameter flu to be erected to exterior of building.

To include 500mm @ 1200 mm long silencer please see attached spec.

New 500mm jet cowl.

New new blanking plate.

All exterior ductwork to be painted (not powder coated) black.

Interior work to include twin carbon filter box to reduce odors with exchangeable filters. Please see attached specifications. .

Photo 3



Photo 6





Photo 7

