

**BURY COUNCIL**  
**DEPARTMENT OF OPERATIONS**

REF NO: 24/260

FROM: Head of Engineering

TO: Head of Development Management

---

Planning Application No: 71260

Location: 329 Brandlesholme Road, Bury, BL8 1HS

Development: Hip to gable loft conversion with rear dormer; Two storey front extension; Single storey side rear extension; Alterations to rear garden/driveway and extension of side vehicular crossing

---

**RECOMMENDATION**

I recommend that any planning permission given shall include the following conditions:

1. The amended access and parking arrangements indicated on the approved plans, incorporating the extension of the existing footway crossing, hardstanding in a permeable/porous material and/or measures to prevent the discharge of surface water onto the adopted highway, demarcation of the limits of the adopted highway and any associated remedial works required to reinstate the footway to its former condition prior to commencement of the development, shall be implemented to the satisfaction of the Local Planning Authority before the extensions and new parking facilities hereby approved are brought into use. (HY08 Amended)
2. The development hereby approved shall not be commenced unless and until facilities for the storage of construction materials have been provided within the curtilage of the site to the satisfaction of the Local Planning Authority. The facilities shall be retained for the intended purpose and the area identified shall not be used for any other purposes other than the storage of construction materials for the duration of the construction period.

**Reasons**

1. To secure the satisfactory development of the site in terms of highway safety, ensure good highway design and maintain the integrity of the adopted highway, all in the interests of highway safety.
2. To maintain the integrity of the adopted highway and ensure adequate off highway materials storage arrangements are provided for the duration of the construction period, in the interests of highway safety.

Cont/.....

### **Comments and Observations**

The applicant's attention is drawn to the need to consult the Department of Operations regarding the specification for and implementation of the required footway crossing extension. The cost of the works will be the responsibility of the applicant. (N004 Amended)

Date: 27 November 2024

Signed: **A Southgate**  
**(pp) Head of Engineering**

**HIGHWAYS ASPECTS ONLY**