

This development would require a HMO licence. For more information they can contact HMOs@bury.gov.uk

It will need a fire risk assessment, to inform the level of detection and coverage required. This is a requirement of the RRO and the HMO licence.