



Your Reference 68994

Our Reference PR1031804

Contact Fire Safety Officer Gill Hoyle
hoyleg@manchesterfire.gov.uk

Chief Fire Officer

Dave Russel, BSc, MIFireE

Greater Manchester Fire and Rescue
Service
146 Bolton Road
Swinton
Manchester
M27 8US

Tel: 0161 736 5866
www.manchesterfire.gov.uk

Bury Council
Knowsley Street
Bury
Lancashire
BL9 0SW

Sent via email - development.control@bury.gov.uk
d.clapworthy@bury.gov.uk

For the attention of Dean Clapworthy

21st October 2022

Dear Sir/Madam,

Planning Application No:	68994
Address:	Land at York Street Radcliffe Manchester
Proposal:	Non-material amendment following approval of planning permission ref no. 56744 - Increase the width of the emergency access road

The above proposal should meet the requirements for Fire Service access.

The Fire Service requires vehicular access for a fire appliance to within 45m of **all** points within the dwellings.

The access road should be a minimum width of 4.5m and capable of carrying 12.5 tonnes. Additionally, if the access road is more than 20m long a turning circle, hammerhead, or other turning point for fire appliances will be required. The maximum length of any cul-de-sac network should be 250 m.

There should be a suitable fire hydrant within 165m of the furthest dwelling.

The Fire Service strongly supports the installation of domestic sprinkler systems as a positive measure to protect persons. At a small cost occupants'

can be given the reassurance of a high level of protection. All developers should positively consider the viability of installing domestic sprinkler systems. The access requirements for a dwelling fitted with an approved sprinkler system can deviate from the required standard detailed above, further consultation will be required.

Yours sincerely

A handwritten signature in black ink, appearing to be a stylized 'A' or 'J' followed by a few dots.

On behalf of the
Greater Manchester Combined Authority