

BURY COUNCIL
DEPARTMENT OF OPERATIONS

REF NO: 25/061

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 71582

Location: 1 Central Street, Bury, BL9 0JN

Development: Advertisement consent for 2 No. internally illuminated fascia signs on runner; 1 No. internally illuminated projecting sign

RECOMMENDATION

I do not wish to restrict the granting of planning permission

Reasons

Comments and Observations

1. The proposed signs have no effect on traffic and it is understood luminance figures are not normally required in pedestrian areas. (N028 Amended)
2. The applicant's attention is drawn to the fact that signs projecting over the footway must be erected with a 2.4m minimum underside clearance. (N022 Amended)

Date: 19 February 2025

Signed: **A Southgate**
(pp) Head of Engineering

HIGHWAYS ASPECTS ONLY