

BURY COUNCIL
DEPARTMENT OF OPERATIONS

REF NO: 24/014

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 70418

Location: 3-5 Princess Parade, Bury, BL9 0QL

Development: 2 No. internally illuminated fascia signs (letters only) and
2 No. internally illuminated projecting suspended signs
internally (letters only)

RECOMMENDATION

I do not wish to restrict the granting of planning permission

Reasons

Comments and Observations

1. The applicant's attention is drawn to the fact that signs projecting over the highway must be erected with a 2.4m minimum underside clearance. (N022 Amended)
2. The proposed sign(s) has/have no effect on traffic and it is understood luminance figures are not normally required in pedestrian areas. (N023)

Date: 12 February 2024

Signed: **A Southgate**
(pp) Head of Engineering

HIGHWAYS ASPECTS ONLY