
TYPICAL KERB STANDARD DETAIL:



K2 - 125 x 255/150 Half Battered Drop Kerb - Left Hand





K3 - 125 x 255/150 Half Battered Drop Kerb - Right Hand




K4 - 125 x 150 Bullnosed Centre Kerb

NTS





CROSS SECTION:



Layer	Thickness (mm)	Clause (MCHW)	Material
Surface Course	20	912	AC6 dense surf 100/150
Base	50	909	AC32 Dense Base 40/60
Sub-base	100	803/806	Type 1 granular sub-base
Subgrade	2.5% < CBR		

NTS

TACTILE PAVING SPECIFICATIONS:

400x400x65mm thick BUFF colour tactile Blister Paver Blocks

25mm compated thickness sand laying course with jointing sand (BS7533-3)

150MM THICK Type 1 granular Sub-base (Clause 803)

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

In addition to the hazards/risks normally associated with the types of work detailed on this drawing, note the following

1. POTENTIAL FOR PRESENCE OF UNDERGROUND UTILITIES RISK. The Contractor shall undertake all necessary utility searches, consultation and site investigations and obtain all required permits/approvals from the relevant statutory undertakers before working in the vicinity of existing apparatus.

It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved method statement


NOTES

1. All dimensions in meters unless noted otherwise.
2. Existing ground at formation level (subgrade) must achieve minimum CBR value of 2.5% before sub-base is laid.
3. Kerbs to be laid on ST4 concrete bed and backing.

Key:

- Site Boundary
- Public Right of Way - Black Lane (Tottington Footpath 63)
- 125 x 225/150 Half Battered Drop Kerb with 125/6mm kerb face
- 125 x 150 BN3 Bull Nose Kerb with 0-6mm kerb face
- Proposed flat top precast concrete edging laid flush
- Proposed asphalt surfacing for footway, in accordance with the local highway authority standards, for further details please refer to Footway Construction Standard Details drawing number MAC21-CTY-HGN-ZZ-DR-D-0003
- Proposed tactile paving in accordance with the local highway authority standards, for further details please refer to Tactile paving specifications shown on drawing number MAC21-CTY-HGN-ZZ-DR-D-0003

Site Location:



REV	AMENDMENTS	DATE	DRAWN
P01	FOR PLANNING	02.10.2026	AH

CLIENT:

Mr & Mrs Mackenzie

project title
DEVELOPMENT AT:
Tom Nook Farm
Turton Road, Tottington, bury, BL83QG

drawing ref: MAC21-CTY-HGN-ZZ-DR-D-0003	scales: As Shown @ A3
drawing title: Tom Nook Farm Footway Construction Standard Details	date: 02.10.2026
drawn: AH / checked: MB	project ref: MAC21 / rev: P01

CITYSTRUCT
Infrastructure Design Services
Two Four Nine North, Lynnfield House
Altrincham WA14 4DZ
Tel: 0330 133 3114
Email: info@citystruct.com
Web: www.citystruct.com

All Rights Reserved
By Citystruct Ltd