

Project name

Silletts Funeral Services - Extension Only As designed

Date: Tue Jul 22 15:49:52 2025

Administrative information

Building Details

Address: Silletts Funeral Services, Radcliffe, Bury,
Manchester, M26 2TQ

Certifier details

Name: David Barsted

Telephone number: 01625 315040

Address: Suite F6.3b, Adelphi Mill, Grimshaw Lane,,
Bollington, SK10 5JB

Certification tool

Calculation engine: SBEM

Calculation engine version: v6.1.e.2

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.28

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 360.6

The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	5.47
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	5.04
Target primary energy rate (TPER), kWh _{PE} /m ² annum	57.3
Building primary energy rate (BPER), kWh _{PE} /m ² annum	52.76
Do the building's emission and primary energy rates exceed the targets?	BER ≤ TER BPER ≤ TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.16	0.16	FF000012_W0
Floors	0.18	0.18	0.18	FF000012_F
Pitched roofs	0.16	0.15	0.15	FF00000D_C
Flat roofs	0.18	0.15	0.15	FF00001D_C
Windows** and roof windows	1.6	1.31	1.31	FF000013_W0_O0
Rooflights***	2.2	1.4	1.4	FF00000D_C_O0
Personnel doors^	1.6	1.1	1.1	FF00001D_W8_O4
Vehicle access & similar large doors	1.3	-	-	No external vehicle access doors
High usage entrance doors	3	-	-	No external high usage entrance doors

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]

U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]

U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check.

*** Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	7

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- Split System

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.8	5	-	-	-
Standard value	2.5*	5	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

1- SYST0001-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	-
Standard value	1	N/A

Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter
NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.	

Zone name	SFP [W/(l/s)]										HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I		Zone	Standard
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1			
GF: Brew	0.3	-	-	-	-	-	-	-	-	-	-	N/A
GF: WC	0.3	-	-	-	-	-	-	-	-	-	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
Standard value		95	80	0.3
GF: Brew		120	-	-
GF: WC		120	-	-
GF: Circ		120	-	-
GF: Chapel 4		120	-	-
GF: Chapel 3		120	-	-
GF: Chapel 2		120	-	-
GF: Store		120	-	-
GF: Reception		120	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
FF		120	-	-
GF: Extension Circ		120	-	-
GF: Chapel 6		120	-	-
GF: Chapel 5		120	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
GF: Brew	N/A	N/A
GF: WC	N/A	N/A
GF: Circ	NO (-36.1%)	NO
GF: Chapel 4	NO (-58.4%)	NO
GF: Chapel 3	NO (-58.6%)	NO
GF: Chapel 2	NO (-59.3%)	NO
GF: Store	N/A	N/A
GF: Reception	NO (-70.5%)	NO
FF	NO (-43.5%)	NO
GF: Extension Circ	NO (-74.4%)	NO
GF: Chapel 6	NO (-80.3%)	NO
GF: Chapel 5	NO (-59.2%)	NO

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	250.9	250.9
External area [m ²]	776.1	776.1
Weather	MAN	MAN
Infiltration [m ³ /hm ² @ 50Pa]	7	3
Average conductance [W/K]	179.99	243.78
Average U-value [W/m ² K]	0.23	0.31
Alpha value* [%]	47.15	30.84

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area	Building Type
	Retail/Financial and Professional Services
	Restaurants and Cafes/Drinking Establishments/Takeaways
64	Offices and Workshop Businesses
	General Industrial and Special Industrial Groups
	Storage or Distribution
	Hotels
	Residential Institutions: Hospitals and Care Homes
	Residential Institutions: Residential Schools
	Residential Institutions: Universities and Colleges
	Secure Residential Institutions
	Residential Spaces
	Non-residential Institutions: Community/Day Centre
6	Non-residential Institutions: Libraries, Museums, and Galleries
	Non-residential Institutions: Education
	Non-residential Institutions: Primary Health Care Building
	Non-residential Institutions: Crown and County Courts
30	General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger Terminals
	Others: Emergency Services
	Others: Miscellaneous 24hr Activities
	Others: Car Parks 24 hrs
	Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	24.48	27.79
Cooling	2.1	2.72
Auxiliary	0.08	0.12
Lighting	6.18	6.08
Hot water	1.28	1.28
Equipment*	7.18	7.18
TOTAL **	34.13	38

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>0</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	338.99	307.21
Primary energy [kWh _{PE} /m ²]	52.76	57.3
Total emissions [kg/m ²]	5.04	5.47

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
	Actual	312.1	26.9	24.5	2.1	0.1	3.54	3.55	3.8	5
	Notional	264.2	43.1	27.8	2.7	0.1	2.64	4.4	----	----

Key to terms

- Heat dem [MJ/m2] = Heating energy demand
- Cool dem [MJ/m2] = Cooling energy demand
- Heat con [kWh/m2] = Heating energy consumption
- Cool con [kWh/m2] = Cooling energy consumption
- Aux con [kWh/m2] = Auxiliary energy consumption
- Heat SSEFF = Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
- Cool SSEER = Cooling system seasonal energy efficiency ratio
- Heat gen SSEFF = Heating generator seasonal efficiency
- Cool gen SSEER = Cooling generator seasonal energy efficiency ratio
- ST = System type
- HS = Heat source
- HFT = Heating fuel type
- CFT = Cooling fuel type