

The fan technical information sent does not give us a sound level at which it will operate. A noise assessment shall be undertaken,

Thanks

Rob Hall

Unit Manager, Commercial Team

Bury Council | Department for Operations | Public Protection

3 Knowsley Place | Duke Street | Bury | BL9 0EJ