

The proposed surface water drainage strategy, which discharges runoff separately to the existing public surface water sewer, is noted.

In accordance with the NPPG, the Non-Statutory Technical Standards for SuDS and the Greater Manchester SuDS Design Guide, clarification is required to demonstrate that exceedance flows (e.g. surcharge or events beyond the design standard) would be managed safely, directed away from buildings, and would not result in flooding of adjacent land or property.

Project Engineer (Drainage)