

From: Greatorex, Shelley <greatorexs@manchesterfire.gov.uk>
Sent: 28 October 2022 15:46
To: Clapworthy, Dean <D.Clapworthy@bury.gov.uk>
Subject: RE: 68994: GMFRS - Planning Application - York Street

Hi Dean,

Apologies for the confusion and delay in responding to your email.

It would appear that we missed of including some information in our response relating to application 68994. We should have included that the emergency access road would need to be a minimum of 3.7m in width between kerbs and be capable of carrying 12.5 tonnes.

I hope that this gives you the required clarification.

Please let me know if you require further information.

Regards,

Shelley