

BURY COUNCIL
DEPARTMENT OF OPERATIONS

REF NO: 25/095

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 71664

Location: Knowsley Hotel, Haymarket Street, Bury, BL9 0AY

Development: Installation of replacement signs to include: 1x Externally illuminated double sided pictorial projecting sign, 2x Externally illuminated fascia signs, 2x amenity boards, 2x poster cases and 1x sign written logo

RECOMMENDATION

I recommend that any planning permission given shall include the following condition:

The luminance of the signs shall not exceed 250cd/m² each. (ADL4 Amended)

Reasons

To avoid undue distraction to traffic in the interests of road safety and to protect the amenity of adjoining occupiers.

Comments and Observations

Date: 26 March 2025

Signed: **A Southgate**
(pp) Head of Engineering

HIGHWAYS ASPECTS ONLY