

From: Planning Applications

Sent: Friday, August 16, 2024 1:41 PM

To: Clapworthy, Dean

Subject: [EXTERNAL] RE: 70284: Application for reserved matters approval (appearance, landscaping, layout and scale) for the erection of 400 dwellings, relocation of cricket pitch, including a pavilion, practice nets and scoreboard, inc. discharge of cons

CAUTION: This email originated from outside the organisation. Be cautious of the email content, if in doubt do not click on any links or open any attachments.

Dear Sir/Madam,

Planning Application – 70284

We have considered the above planning application and find it could have an impact on our infrastructure.

The development is shown to be adjacent to or affect Electricity North West's operational land or electricity distribution assets. Where the development is adjacent to operational land the applicant must ensure that the development does not encroach over either the land or any ancillary rights of access or cable easements. If planning permission is granted the applicant should verify such details by contacting Electricity North West, Land Rights & Consents, Frederick Road, Salford, Manchester M6 6QH.

The applicant should be advised that great care should be taken at all times to protect both the electrical apparatus and any personnel working in its vicinity. The applicant should also be referred to two relevant documents produced by the Health and Safety Executive, which are available from The Stationery Office Publications Centre and The Stationery Office Bookshops, and advised to follow the guidance given.

The documents are as follows:-

HS(G)47 – Avoiding danger from underground services.

GS6 – Avoidance of danger from overhead electric lines.

The applicant should also adhere to the minimum safety clearances contained within the Energy Network Associations Guidance, a copy of which is also attached to this email.

Furthermore, should there be a requirement to divert the apparatus because of the proposed works, the applicant should be advised that the cost of such a diversion would usually be borne by the applicant. The applicant should be aware of our requirements for access to inspect, maintain, adjust, repair, or alter any of our distribution equipment. This includes carrying out works incidental to any of these purposes and this could require works at any time of day or night. Our Electricity Services Desk (Tel No. 0800 195 4141) will advise on any issues regarding diversions or modifications.

Electricity North West offers a fully supported mapping service, at a modest cost, for our electricity assets. This is a service which is constantly updated by our Data Management Team who can be contacted by telephone on 0800 195 4141 or access the website [Know before you dig \(enwl.co.uk\)](https://www.enwl.co.uk)

It is recommended that the applicant gives early consideration in project design as it is better value than traditional methods of data gathering. It is, however, the applicant's responsibility to demonstrate the exact relationship on site between any assets and rights that may cross the site and any proposed development.

Yours sincerely,

Asset Protection
Land Rights & Consents
Electricity North West
Frederick Road
Salford
M6 6QH