

- Civil Engineering
- Structural Engineering

26/07/2021

ELLUC Project responses regarding the Morris Street project

Planning Condition 14 - Proposed Development at Morris Street will not negatively impact the ecology of the River Irwell. The foul water for the site will be discharge to the existing UU combined manholes within the street parallel to Dumers Lane (south of Hassall Street). There is an existing surface water sewer which runs through the proposed development which discharges into the River Irwell via headwall. Our proposed surface water drainage will discharge into the existing surface water sewer, utilising the existing headwall outfall, therefore, we will not be reconstructing or creating any disturbances to the River Irwell ecology / bank.