

ENGINEERING CONSULTANCY SERVICES

DRAINAGE CONSULTATION

Date: 08/10/25

Your Ref: 72313

Location: Land at rear of 354 Manchester Road, Bury, BL9 9NR

Proposal: Erection of 1 no. dwelling

RECOMMENDATIONS

No objections to the proposed development subject to the following:

CONDITION: Development shall not commence until details of surface water drainage proposals have been submitted to and approved by the Local Planning Authority. The scheme must be based on the hierarchy of drainage options in the National Planning Practice Guidance and be designed in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or subsequent revisions of it. This must include assessment of potential SuDS options for surface water drainage with appropriate calculations and test results to support the chosen solution. Design details should comply with guidance contained in the Greater Manchester's Sustainable Drainage Design Guide, March 25. Details of proposed maintenance arrangements should also be provided

REASON: To promote sustainable development. The current application contains insufficient information regarding the proposed drainage scheme to fully assess the impact.

Informative Notes for the Applicant

N039	The site is to be drained on a separate system of drainage with surface water and foul sewage being combined at the last manhole before connection to public sewer
N040	Surface water discharge to be limited to existing flow from site less a minimum 40% reduction in run-off to allow for climate change to prevent surcharge of public sewerage system downstream of the proposed development Chapter 10 of the National Planning Policy Framework - Meeting the Challenge of Climate Change, Flooding and Coastal Change and Unitary Development Plan Policy EN5/1 - New Development and Flood Risk and its associated SPD 16 Design and Layout of New Development in Bury. Climate change allowance should be increased to 70% for sites which fall within Flood Zone 3
N041	Application forms for permission to connect to the public sewer should be obtained by telephoning United Utilities PLC on 08456 020406 or online at www.unitedutilities.com
N042	Applications for Building Over Agreements or sewer diversions should be obtained by telephoning United Utilities PLC on 01925 464714.
N044	Approval for a surface water connection to the watercourse should be obtained from: <i>Ordinary Watercourse</i> – Bury Council, Engineering and Streetscene https://www.bury.gov.uk/index.aspx?articleid=11128
N048	A culverted watercourse, the responsibility of riparian owners, passes through the site. This culverted watercourse is classified as an ordinary watercourse and Bury Council, Engineering

	Design and Construction Group should be consulted regarding this application.
N049	The applicant should plot the exact line of the culverted watercourse in relation to any proposed buildings.
N050	Without the approval of the Bury Council, Engineering Design and Construction Group no building is to be constructed or works carried out within 3m of the centreline of a culverted watercourse.
N051	Approval for any works above or adjacent to a culverted watercourse should be obtained from: <i>Ordinary Watercourse</i> – Bury Council, Engineering and Streetscene https://www.bury.gov.uk/index.aspx?articleid=11128
N052	The applicant should note that a 150mm diameter combined sewer passes through the proposed development. The applicant must plot the exact position of the public sewer in relation to any proposed buildings.
N053	No building should be constructed within 3m of the centreline of the public sewer without the approval of United Utilities PLC.
N105	The applicant should ensure that any proposed driveways/paved areas (in excess of 5m ²) situated at the front of properties are constructed of permeable or porous materials. The applicant should refer to Dept. of Communities & Local Government publication “Guidance on the Permeable Surfacing of Front Gardens” for design & construction details.



Andy Southgate
Group Manager
Major Projects Group
Engineering and Streetscene