

The submitted information has been reviewed and the surface water drainage strategy is considered acceptable in principle.

Nonetheless, it is noted that surface water is proposed to discharge to the public surface water sewer, whilst foul flows will discharge separately to the existing combined sewer. In this regard, the comments from United Utilities concerning the need for further detailed drainage information and the assessment of potential sewer surcharge should be duly considered.

Drainage Engineer

Bury
Council