

PROJECT: Radcliffe Hub 5860 DATE: 14/04/2023

SUBJECT: RE: 69388: (P5860) RE: Initial Consultation on Planning Application - Radcliffe Civic Hub, 13-21 Blackburn Street, Radcliffe, Manchester, M26 1NN - Contaminated Land, Air Quality and COPA TRANSMITTAL ID: 00008

PURPOSE: For your review and comment VIA: Info Exchange

FROM

NAME	COMPANY	EMAIL	PHONE
Alex Hawkins	Pozzoni Architecture	alex.hawkins@pozzoni.co.uk	

TO

NAME	COMPANY	EMAIL	PHONE
d.clapworthy@bury.gov.uk		d.clapworthy@bury.gov.uk	

REMARKS: Good morning Dean,

We have received some further information in response to two of the items raised:

- (i) *A copy of Arup desk study completed in April 2021.*
 - Please see the attached Arup Desk Study dated 2021 which was issued as part of the tender docs.
- (iv) *Clarification of the where the samples were taken from in WS04 and BH06 as the depths on the certificates of analysis and borehole logs do not match.*
 - Please see the attached updated ID Geo Geoenv report
 - BH06 The sample depths were carried through incorrectly from the log to BH05. The correct sample depths are now shown as 1.40-1.7m and 2.2-2.5m which accords with the sample depths on the laboratory test certificate and summary tables.
 - WS04 The sample depth was shown as 0.9-1.0m. This has been corrected to 0.8-1.0m which accords with the laboratory test certificate and summary tables.

We are working to respond to the other points raised.

Kind regards,

Alex Hawkins.
Project Architect

Transmittal

DATE: 14/04/2023
TRANSMITTAL ID: 00008



0161 928 7848 | alex.hawkins@pozzoni.co.uk | www.pozzoni.co.uk

DESCRIPTION OF CONTENTS

QTY	DATED	TITLE	NOTES
1	14/04/2023	Appendix 2 - Radcliffe Constraints Desk Study_Issue2 130423.pdf	
1	14/04/2023	RADHUB-IDG-XX-XX-SU-G-0001_ID Geo Full Site Investigation_S2 - Suitable for Information_B_1.pdf	
1	14/04/2023	RADHUB-IDG-XX-XX-SU-G-0001_ID Geo Full Site Investigation_S2 - Suitable for Information_B_2.pdf	

COPIES:

David Spoors	(Pozzoni Architecture)
Alex Hawkins	(Pozzoni Architecture)