

Please see my comments below and attached letter response. I have changed the wording of CLA2 below, as CLA1 is not required.

CONTAMINATED LAND – CONDITION.

The site has historically been in use as open fields with a small building on site. Additional outbuildings were developed between 1893 and 1930. Surrounding historical uses were predominantly rural with farmhouses and in the wider area cotton mills, ponds and quarries. Currently the site is occupied by a steel framed shed surrounded by fields and some residential.

The site is not within 250m of a registered landfill. The site is situated above the Lower Coal Measures Formation Secondary A Aquifer overlain by Glacial Till.

The proposal is to convert the garage building to residential.

In line with the National Planning Policy Framework, the site is proposed for a sensitive end use we recommend that the following contaminated land conditions are placed on any grant of permission:

- **CLA2 - Contaminated Land implementation of Remediation Strategy and Site Verification Report:** The approved Remediation Strategy (Geo-Environmental Audit, Phase 1, Preliminary Risk Assessment, Phase 3 Remediation Statement, Proposed Commercial Development, 2 Taylors Lane, Bolton, BL2 6QS, TJ Booth Associates, March 2023) must be carried out to the satisfaction of the Local Planning Authority within agreed timescales; and A Site Verification Report detailing the actions taken and conclusions at each stage of the remediation works, including substantiating evidence, shall be submitted to and approved in writing by the Local Planning Authority prior to the development being brought into use.

Reason - To secure the satisfactory development of the site in terms of human health, controlled waters and the wider environment and pursuant to Planning Policy Statement 23 - Planning and Pollution Control.

Asbestos Condition - Prior to demolition of the structures on site an asbestos survey is to be carried out by an appropriately qualified contractor. Any asbestos identified shall be disposed of in an appropriate manner.

Reason: This is to secure the satisfactory development of the site in terms of human health, controlled waters and the wider environment and pursuant to the National Planning Policy Framework.

AIR QUALITY – CONDITION

The site is not located within an Air Quality Management Area. Due to the scale of the development, it is considered unlikely that the development would create an increase of more than 500 AADT (annual average daily traffic). Therefore, in line with the EPUK Guidance, an air quality assessment will not be required.

Bury Council has been identified by DEFRA as an area requiring to significantly improve air quality. The required measures to do this are currently under discussion. Due to this requirement, and the requirements of the new building regulations (The Building Regulations 2010, Approved Document S, Infrastructure for the charging of electric vehicles), this Section recommends the following condition to be placed on any grant of permission:

- **Residential with dedicated parking spaces:** Prior to occupation the applicant shall provide one electric vehicle (EV) charging point (minimum 7kW*) per unit (dwelling with dedicated parking).

*Mode 3, 7kW (32A) single phase, or 22kW (32A) three phase, and for 50kW Mode 4 rapid charging may be required. British Standard BS EN 61851-1:2019 to be used. Further information regarding minimum standards can be found at <https://www.gov.uk/transport/low-emission-and-electric-vehicles>.

Reason: In accordance with the NPPF, to encourage the uptake of ultra-low emission vehicles and ensure the development is sustainable. To safeguard residential amenity, public health and quality of life.

**Operations – Environment Section.
27 April 2023**

INFORMATIVE - The Control of Noise (Appeals) Regulations 1975, Section 60. Control of Noise on Construction Sites

Works carried out in connection with the planning permission shall comply with the above regulations which require the following:

1. All works and ancillary operations which are audible at the boundary of the nearest house or noise receptor, or at such other place as may be agreed with the Council, shall be carried out only between the hours of 0800 and 1800 on Mondays to Fridays and between the hours of 0900 and 1400 on Saturdays and at no time on Sundays and Bank Holidays.
2. The best practicable means, as defined in section 72 of the Control of Pollution Act 1974, to reduce noise to a minimum shall be employed at all times.
3. All plant and machinery in use shall be properly silenced and maintained in accordance with the manufacturer's instructions.
4. Any emergency deviation from the above (1 – 3) shall be notified to Bury Council without delay.

Any contravention of these requirements will trigger the serving of a Notice under Section 60 of The Control of Noise Regulations 1975.

Thank you

**Operations – Environment Section.
19 September 2023**